

PAINT GRADE

FD30 35mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 35mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF573).

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings. Wood veneer face with a flaxboard core.

Door Codes

IPL35F

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles: Softwood min 28mm (nominal)
Rails (outer): Softwood min 22mm (nominal)
Rails (inner): Softwood min 28mm (nominal)
Core: Flaxboard
Lockblock: N/A
Lipping: 6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Cutting of apertures or glazing on site is not permitted and invalidates the fire certification. Third party BWF-Certifire licensed processors are able to complete this ancillary work when required.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings. Wood veneer face with a tubular chipboard core.

Door Codes

IPLF

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles: Softwood min 38mm (nominal)
Rails (outer): Softwood min 32mm (nominal)
Rails (inner): Chipboard min 38mm (nominal)
Core: Tubular chipboard
Lockblock: N/A
Lipping: 6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Cutting of apertures or glazing on site is not permitted and invalidates the fire certification. Third party BWF-Certifire licensed processors are able to complete this ancillary work when required.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

SOLID CORE

– EXTERNAL DOOR

SPECIFICATIONS

Construction

Flush face with softwood stiles and rails and complementing exposed hardwood lippings. Wood veneer face with a tubular chipboard core.

Door Codes

F1X

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails:	Softwood min 32mm (nominal)
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour (exposed)

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for hi-build paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the manufacturing identifications.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE STANDARD CORE – INTERNAL DOOR

SPECIFICATIONS

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings. Wood veneer face and a cellular core.

Door Codes

Imperial 35mm: IPL3

Metric 40mm: IPL5

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood MDF board.

Components

Stiles: Softwood min 28mm (nominal width)

Rails: Softwood min 28mm (nominal width)

Core: Cellular

Lockblock: Chipboard

Lipping: N/A

Lock Area

A lock-block is positioned centrally to one side of the door which is indicated by the word "LOCK" to the top edge. This is an area of 320mm high x 55mm wide.

Finish

Supplied unfinished for paint finish only. (Staining is not recommended)

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge.

The top of the door should not be trimmed due to the manufacturing identifications.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC01/GW01 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC01/GW01

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC05/GW05 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC05/GW05

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC06/GW06 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC06/GW06

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC07 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF160).
Glazed with 7mm Pyrodur Plus clear glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a flaxboard core.

Door Codes

IPLF+GC07

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC08 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 7mm Pyrodur Plus clear glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular core.

Door Codes

IPLF+GC08

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC09 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF160).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a flaxboard core.

Door Codes

IPLF+GC09

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Flaxboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC10/GW10 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC10/GW10

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC11/GW11 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC11/GW11

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC12/GW12 GLAZED FD30 44mm – INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC12/GW12

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC13 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC13

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.



PAINT GRADE

GC 14 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF192).
Glazed with 6mm Pyroclear or 7.2mm PyroShield2 wired glass.

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings.
Wood veneer face with a tubular chipboard core.

Door Codes

IPLF+GC14

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 38mm (nominal)
Rails (outer):	Softwood min 32mm (nominal)
Rails (inner):	Chipboard min 38mm (nominal)
Glazing framing:	6mm hardwood lining
Glazing bead:	Meranti or MDF
Core:	Tubular chipboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door, maximum dimensions specified on installation instructions provided.

Finish

Supplied un-finished for paint finish only (staining is not recommended).

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

Re-decorate the door as necessary always following the paint manufacturer's instructions.

