

**CERTIFICATE OF APPROVAL
No CS 5011**

This is to certify that, in accordance with
STS200 General Requirements for Certification of Enhanced Security Products
The undermentioned products of

JELD-WEN UK LTD

**Retford Road, Woodhouse Mill, Sheffield,
South Yorkshire, S13 9WH
Tel: 0114 229 3250 Fax: 0114 229 3260**

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:


CERTIFIED PRODUCT
Securefit Timber Doorsets

TECHNICAL SCHEDULE
STS201 - Enhanced security
requirements for doorsets to
satisfy the requirements of
PAS24

CLASSIFICATION			
Security	Weather	Strength	Material Specific
PAS24 DKT	BS6375-1 800U	BS6375-2 Medium Duty	BS644

NPD = No performance determined

**Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification**



**Sir Ken Knight
Chairman
Impartiality Committee**



**Paul Duggan
Certification Manager**

Issued: 6th December 2011
Reissued: 22nd February 2017
Next audit test due: 15th February 2018
Frequency: Annually
Valid to: 21st February 2022

Page 1 of 4



CERTIFICATE No CS 5011
JELD-WEN UK LTD

JELD-WEN UK Ltd – Securefit Timber Doorsets

1. This approval relates to the use of the above in providing an enhanced security performance to PAS24:2012 annex A & annex B clauses B.4.3, B.4.4, B.4.5, B.4.6, B.4.7, B.4.8, B.4.9 for key-key and key-thumbturn operation, a weather performance of 800U to BS6375-1:2015 and a mechanical strength performance of Medium Duty to BS6375-2:2009.
2. The doorsets are approved on the basis of:
 - i. Initial type testing against PAS24 & BS6375. Exova test reports WIL307023, WIL307024A, WIL307024B, WIL324216, WIL339312, WIL343703, WIL343869 & WIL358824.
 - ii. Audit testing at the frequency specified in STS 200 & STS 201 where relevant.
 - iii. A design appraisal against STS201 where relevant.
 - iv. Inspection and surveillance of factory production control at Retford Road, Woodhouse Mill, Sheffield, South Yorkshire, S13 9WH.
3. This approval is applicable to complete doorsets only.
4. This certification is designed to demonstrate compliance of the doorset specifically with PAS24 and the requirements of Secured by Design. If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
5. This approval is applicable to single-leaf, unglazed, open-in doorsets without sidelights & toplights, with or without letterplates at leaf dimensions up to those given in Table 1.
6. Approved hardware items are:
 - 3no. Nico 4542 Heavy Butt Hinge or 3no. Cooke Brothers Grade 13 Hinge
 - ERA MPL Holiday multipoint lock with handle or key engagement
 - Mila ProSecure E Variant 92 handle
 - Mila KM535608 Anti Bump Cylinder or ISEO KM544418 F6 Cylinder

For the full specification of the product please refer to the constructional specification that accompanies this certificate.

**CERTIFICATE No CS 5011
JELD-WEN UK LTD**

JELD-WEN UK Ltd – Securefit Timber Doorsets

Configuration	Maximum door leaf width (mm)	Maximum door leaf height (mm)	Door leaf thickness (mm)
Open-in, single leaf *	936	2040	54

Table 1. Permitted Door Leaf Dimensions

Configuration	Maximum frame width (mm)	Maximum frame height (mm)
Single leaf without toplights & sidelights*	1016	2097

Table 2. Permitted Frame Dimensions

* ensuring maximum glazing sizes are not exceeded.

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTISECURE approval.

7. The doorsets shall be mechanically fixed to wall constructions as described in manufacturers approved installation instructions.
8. Labels to the EWCL design referencing CERTISECURE, PAS24 DKT, JELD-WEN UK Ltd, and CERTISECURE certificate No. CS 5011 shall be affixed to each doorset in the prescribed position.
9. This approval relates to on going production. The doorset and/ its immediate packaging is identified with the manufacturer’s name, the product name or number, the CERTISECURE name and mark together with the CERTISECURE Certificate number and application where appropriate.



CERTIFICATE No CS 5011
JELD-WEN UK LTD

Further Information

Further information regarding the details contained in this report may be obtained from JELD-WEN (UK) Ltd, Woodhouse Mill, Sheffield, South Yorkshire, S13 9WH (Tel: 0114 229 3250, Fax: 0114 2293260)

Further information regarding CERTISECURE certification and other approved products can be obtained from Exova Warrington Certification Limited, Holmesfield Road, Warrington WA1 2DS (Tel: 01925 646777).

Page 4 of 4 Signed
E/128

Two handwritten signatures in black ink, one appearing to be "Paul" and the other "Hogg".

Issued: 6th December 2011
Reissued: 22nd February 2017
Valid to: 21st February 2022