

REAL WOOD VENEER

FD30 35mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 35mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF573).

Construction

Flush face with softwood stiles and rails and complementing hardwood lippings. Over veneered with a flaxboard core.

Door Codes

Ash	ASHOV35F
Beech	BCHOV35F
Koto	KOTOV35F
Sapele	SAPOV35F
White Oak	WOKOV35F
Walnut	WALOV35F

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

3.2mm veneered wood fibre board.

Components

Stiles:	Softwood min 28mm (nominal width)
Rails (outer):	Softwood min 28mm (nominal width)
Rails (inner):	Chipboard min 38mm (nominal width)
Core:	Flaxboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles maybe fitted centrally in height either side of the door.

Finish

Fully finished no further decoration required to the two faces, finish the four edges with clear lacquer or varnish after trimming.

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge. The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.

All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame. 1mm intumescent sheets are supplied with the door for use around lock/latch area.

Cutting of apertures or glazing on site is not permitted and invalidates the fire certification. Third party BWF-Certifire licensed processors are able to complete this ancillary work when required.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

