

REAL WOOD VENEER

GC09 GLAZED FD30 44mm

– INTERNAL FIRE DOOR

SPECIFICATIONS

Fire Rating

FD30 44mm 30minute to BS476:Part 22: 1987 (CERTIFIRE CF5143).
Glazed with 6mm Pyroclear glass.

Construction

Flush face with complementing hardwood lippings.
Over veneered face with a flaxboard core.

Door Codes

	Clear Glazed
Ash	ASHOVF+GC09
White Oak	WOKOVF+GC09
Beech	BCHOVF+GC09
Sapele	SAPOVF+GC09
Koto	KOTOVF+GC09
Walnut	WALOVF+GC09

Moisture Content

10% (+/-2%) in accordance with BS:EN942.

Facings

0.6mm real wood veneer.

Components

Stiles:	N/A
Rails (outer):	N/A
Rails (inner):	N/A
Glazing framing:	6mm Hardwood liner
Glazing bead:	Meranti or MDF
Core:	Flaxboard
Lockblock:	N/A
Lipping:	6mm hardwood complementing in colour

Lock Area

Locks and handles may be fitted centrally in height either side of the door.

Finish

Fully finished no further decoration required to the two faces, finish the four edges with clear lacquer or varnish after trimming.

Maximum Trim

6mm from the bottom of the door and 4mm from each vertical edge.
The top of the door is not allowed to be trimmed due to the BWF-Certifire fire certification label and manufacturing identifications.

Installation Note

The doors have been tested to BS476 pt 22:1987 and are approved by BWF-Certifire of being capable of achieving 30 minute fire resistance when fitted in accordance with the installation instruction delivered with every door.
All doors must be fitted with intumescent strips to the top and sides of the door leaf or frame.

Maintenance

We recommend wiping down all surfaces with a clean damp cloth at least 4 times per year. We do not recommend using cleaning solutions or abrasive materials as this will damage the door.

